

PROCUREMENT DEPARTMENT
Rm 120 Municipal Services Building
Philadelphia, PA 19102-1685
FAX: (215) 686-4716

CITY OF PHILADELPHIA

Hugh Ortman
Procurement Commissioner

September 29, 2009

BID NUMBER: T0YC2170
TITLE: Refurbishing & Rehabilitation of Hydraulically Operated Inlet Cleaning Buckets
DEPARTMENT: WATER
DATE TO OPEN: September 30, 2009 at 10:30 AM

ADDENDUM # 1

TO ALL BIDDERS:

You are hereby notified of the following changes to the above mentioned bid:

The bid opening date for Bid #T0YC2170 will be postponed to October 7, 2009.

Page 12, Items 2.3.2.2, 2.3.2.3; Page 13 2.5.6, 2.5.7; Page 20 5.3.2, and 5.3.3 has been deleted in its entirety and is being replaced with the following:

2.3.2.2 Install new piston rod assembly consisting of the following:

- a) One (1) new 3 ½ " diameter x 2" long cast iron piston
- b) One (1) new 1 ½ " diameter x 16 ¾ " long chrome plated carbon steel piston rod with Nylok nut
- c) All miscellaneous 'O' rings, seals and wipers

2.3.2.3 Install new cylinder assembly consisting of the following:

- a) One (1) new 4" diameter x 2 ¾ " long cast iron cylinder nut
- b) One (1) new 4" OD x 3 ½ " ID x 14-3/16" long honed carbon steel hydraulic tubing
- c) All miscellaneous 'O' rings, seals and wipers and elbows

2.5.6 **26084-004-008**
1 ½" diameter x 16 ¾" long piston rod assembly (5 each)

2.5.7 **26084-004-009**
4" OD x 3 1/2" ID x 14-3/16" long cylinder assembly (5 each)

	Qty	Unit of Measure	Unit Price	Amount
5.3.2 26084-004-008 1 1/2" diameter x 16 3/4" long piston rod assembly	5	EA	\$_____	\$_____
5.3.3 26084-004-009 4" OD x 3 1/2" ID x 14-3/16" long cylinder assembly	5	EA	\$_____	\$_____

Please sign, date and return this addendum with your bid to the Procurement Department, 1401 J.F.K Boulevard, Bid Room 170A, Philadelphia, PA 19102-1685 as it now becomes a part of the proposal.

Buyer, R. Saylor

AUTHORIZED SIGNATURE

FIRM NAME (PRINT)

DATE

RS/mv